



**Middle Atlantic Products, Inc.**

an ISO 9001:2000 Registered Company

**Title:** MPR-9 installation issues - affects WRK, MRK, VRK, and DRK series enclosures when installed with Riser or Caster base

**PRODUCT SERIES:** MPR-9

**SPECIFIC MODELS:**

**PURPOSE:** Address incompatibility of MPR-9 when installed in certain racks with riser or caster bases

---

The MPR-9 modular power raceway, designed to accommodate 9 power modules, will not fit in a 44 space DRK, WRK, MRK, or VRK series rack if a caster base or inner riser base has been installed. Due to the length of the MPR-9 the lower section extends into the bottom of the rack – this space is filled by the caster base or inner riser base when used. Because the MPR raceways are terminated with a junction box, and need to be permanently wired, racks with the MPR-9 installed are usually stationary. If it is necessary to include more than the 6 modules allowed by the MPR-6 into a 44 space rack with a caster or inner riser base installed, we recommend that multiple raceways be used.

MPR-9 does not fit the following racks when used with caster base or inner riser base:

DRK-44  
WRK-44  
MRK-44  
VRK-44